

Ronald G. Rios
Freeholder Director

Kenneth Armwood
Deputy Director

Claribel A. Azcona-Barber
Charles Kenny
Leslie Koppel
Shanti Narra
Charles E. Tomaro
Freeholders



Shanti Narra
Chairperson,
Public Safety & Health

John A. Pulomena
County Administrator

Joseph W. Krisza
Department Head

Mike Gallagher
Fire Marshal

DEPARTMENT OF PUBLIC SAFETY & HEALTH

Office of the Fire Marshal

Fire Safety Fact Sheet

Propane Pedestal Heaters

As COVID-19 has led to an increase in restaurants offering outdoor dining there has been a look into outdoor dining extending into colder months. We have assembled this list to aid in your restaurant's decision to use these heaters safely. Please use this fact sheet as a guide but please also refer to the manufacturer's instructions for safe maintenance and operation.

- Fuel burning appliances, such as these, are for outdoor use only, with attention to the clearances listed below. **They cannot be used under canopies or tents at any time.**
- The fuel burning appliance must be commercially rated.
- Locations during use:
 - Maintain clearance of at least five feet horizontally from structures and overhangs.
 - Maintain a minimum clearance of three feet vertically and two feet horizontally from combustibles or farther if manufacturer's specifications dictate a farther distance. Must be approved by Fire Marshal.
 - Maintain a clearance of twenty feet from all tents and canopies.
 - Do not block egress ways or sidewalks
- Locations for storage:
 - Ensure that storage of the heaters is secure when not in use
 - Indoor storage of propane cylinders shall be approved by the Fire Marshal.
 - Indoor storage of cylinders may not be in a basement.
 - Cylinder storage must be at least five feet from an exit door.



Prior to approval the following must be submitted to the Fire Marshal's office:

- Permit application completed
- A drawing of the proposed layout of heaters, tables and canopies
- The specifications of the heating unit(s)
- The proposed cylinder storage location

If you have any questions, feel free to contact the Middlesex County Fire Marshal's Office for assistance.

1001 Fire Academy Drive
Sayreville, NJ 08872
Phone Number: (732) 316-7171
Fax: (732) 721-7486
firemarshal@co.middlesex.nj.us

